



WALL WITH 2:1 BACKFILL SLOPE				
WALL HEIGHT	FOOTING WIDTH	VERTICAL BARS	FOOTING DEPTH	KEY WIDTH/DEPTH
3'-0"	1'-10"	#4 @ 32"O.C.	12"	6" X 6"
4'-0"	2'-9"	#4 @ 32"O.C.	12"	12" x 12"
4'-8"	3'-3"	#4 @ 24"O.C.	14"	12" x 14"
6'-0"	4'-6"	#4 @ 24"O.C.	14"	12" x 22"

WALL WITH LEVEL BACKFILL				
WALL HEIGHT	FOOTING WIDTH	VERTICAL BARS	FOOTING DEPTH	KEY WIDTH/DEPTH
3'-0"	1'-9"	#4 @ 32"O.C.	12"	6" X 6"
4'-0"	2'-9"	#4 @ 32"O.C.	12"	6" X 8"
4'-8"	3'-0"	#4 @ 24"O.C.	14"	12" x 12"
6'-0"	3'-9"	#4 @ 24"O.C.	14"	12" x 20"

SPECIAL DISTRICTS DATE 1/08

APPROVED BY  PUBLIC WORKS DIRECTOR/  
CITY ENGINEER

DIVISION MANAGER INITIAL 

CITY OF MORENO VALLEY

PREPARED BY CAPITAL PROJECTS

2 of 2

**RETAINING WALL SECTIONS FOR ELECTRICAL FACILITIES**

NO. **609B**