



LEGEND:

1. SMOOTH TOUCH STAINLESS STEEL. BACKFLOW COVER WITH VANDAL PROOF LOCKING DEVICE.
2. BACKFLOW PREVENTER
3. ANCHOR ROD (TYPICAL)
4. 3250 PSI POURED CONCRETE BASE - 8" MINIMUM THICKNESS THAT EXTENDS 6" BEYOND OUTSIDE DIMENSIONS OF ENCLOSURE AND 3' ON THE HINGED SIDE OF THE ENCLOSURE.
5. WATER SERVICE INLET PIPING
6. WATER SERVICE OUTLET PIPING
7. FINISH GRADE
8. THRUST BLOCK, TYP OF 2

NOTES:

1. USE OF EXPANDED METAL REQUIRES SANDBLAST AND POWDERCOATING. (COLOR DETERMINED BY SPECS.)
2. UNIT REQUIRES SUBMITTAL AND APPROVAL OF SHOP DRAWINGS.

PARKS AND COMMUNITY SERVICES		DATE	01/09	CITY OF MORENO VALLEY PREPARED BY CAPITAL PROJECTS
APPROVED BY		DIVISION MANAGER INITIAL		
 PUBLIC WORKS DIRECTOR/ CITY ENGINEER		 DIVISION MANAGER INITIAL		2 of 2 NO. 630B
DOUBLE BACKFLOW COVER				